



WASHINGTON ASSOCIATION OF BUILDING OFFICIALS
SPECIAL INSPECTION REGISTRATION PROGRAM

**AGENCY FACILITIES, EQUIPMENT, RECORDS, AND
PERSONNEL SURVEY CHECKLIST**

(4/25)

Survey Preparations by The Agency

On the day of the agency survey/inspection, the agency should:

- ___ Have a conference room in which the survey/inspection team and the supervising laboratory technician can meet and work
- ___ Have supervising testing personnel available and prepared to participate
- ___ Have samples all applicable equipment available (including any item on the list of field or laboratory equipment needed to perform the test or inspection in each of the categories for which the agency has applied for registration)
- ___ Have testing and project records accessible for review

1. AGENCY AND KEY PERSONNEL

Survey/Inspection Date: _____

Agency Name _____

Phone No.: _____ Email: _____

Agency Physical Address: _____
Number and Street

City _____ State _____ Zip Code _____

Agency Mailing Address: _____
Number and Street

City _____ State _____ Zip Code _____

Agency Contact: _____
Title/Position

Federal Employer (Tax) Identification Number (EIN): _____

Technical Director _____

Technical Director Involved In Internal Audit Process? ___ Yes ___ No

Supervising Laboratory Technician _____

Special Inspection Field Supervisor _____

Special Inspection Field Supervisor _____

Special Inspection Field Supervisor _____

AGENCY SURVEY CHECKLIST

Registration is for the following type(s) of (testing and inspection) work:

- | | |
|---|--|
| <input type="checkbox"/> Reinforced Concrete (RC)* | <input type="checkbox"/> Spray-Applied Fire-Resistive Materials (FP) |
| <input type="checkbox"/> Prestressed Concrete (PC)** | <input type="checkbox"/> Structural Wood (SWD) |
| <input type="checkbox"/> Shotcrete (SC)** | <input type="checkbox"/> Mass Timber (MT)*** |
| <input type="checkbox"/> Structural Masonry (SM) | <input type="checkbox"/> Cold-Formed Steel Framing (CF) |
| <input type="checkbox"/> Structural Steel and Bolting (SSB) | <input type="checkbox"/> Post-Installed Anchors (PA) |
| <input type="checkbox"/> Structural Welding (SW) | <input type="checkbox"/> Fire-Resistant Penetrations and Joints (FS) |

* Requires current ACI certification as an ACI Field Technician Grade 1.

** Reinforced Concrete registration is a prerequisite for obtaining this agency registration.

*** Structural Wood registration is a prerequisite for obtaining this agency registration.

WABO Agency Inspection Team:

_____	_____
Name	Name
_____	_____
Name	Name

Agency Survey Explanation:

Registration of an agency is based on an assessment of an Agency Registration Application, and accompanying Applicant Qualification Documentation, and an agency on-site facilities, equipment, and records survey/inspection. Below is a list of the items the survey/inspection team will confirm when inspecting an agency.

Agency Survey Team Directions:

For items below, if an item is confirmed place a check in the space; if an item is deficient, place a number in the space to coincide with the numbered deficiency explanations on the final page of this checklist.

2. QUALITY ASSURANCE

- ☐ Confirmed sample pickup procedures
- ☐ Confirmed sample pickup transportation methods
- ☐ Confirmed sample log-in system
- ☐ Confirmed sample marking methods
- ☐ Confirmed sample sorting/storage methods
- ☐ Confirmed method of correcting logbook entry errors
- ☐ Confirmed records include sample receipt date
- ☐ Confirmed traceability of samples to inspection reports and testing reports issued by the agency
- ☐ Confirmed technical director signing off on all final summary letters to AHJ's

AGENCY SURVEY CHECKLIST

DIRECTIONS: Obtain at least three (3) different commercial construction projects (one large concrete project, a masonry project, and one small to medium concrete project) and select samples received approximately three to six months prior to the audit to ensure all the tests and reports should be in a completed file.

<u>Job/ID Name/No</u>	<u>Date Cast</u>	<u>Sample ID No</u>	<u>Sample Type</u>	<u>Break – Log Value</u>	<u>Report Value</u>

Section 2 Inspector Notes:

3. EQUIPMENT CALIBRATION AND MAINTENANCE

DIRECTIONS: Copy the ID No., description, and calibration sticker information (e.g. date due) of six different types of equipment surveyed in the lab. Include any and all nonconforming items found. Use this list to complete the checking of the calibration records and equipment lists in the Records Section.

<u>Equipment ID No</u>	<u>Description</u>	<u>Calibration Sticker</u>	<u>Equipment Log Entry</u>	<u>Calibration Documentation</u>

Section 3 Inspector Notes:

AGENCY SURVEY CHECKLIST

4. REGISTRATION CATEGORIES/TYPES OF WORK

4.1 REINFORCED CONCRETE AND PRESTRESSED CONCRETE

4.1.1 Laboratory Equipment:

- ☐R Confirmed adequate facilities for curing concrete specimens in accordance with ASTM Method C192
(**NOTE:** These facilities may consist either of a thermostatically controlled fog room with required temperature and humidity control or thermostatically controlled tanks containing saturated lime solution.)
- ☐ Confirmed curing room temperatures and humidity are being maintained, or
- ☐ Confirmed curing tank temperature, humidity and water solutions are being maintained
- ☐R Confirmed a screw (or hydraulic) type compressive testing machine with sufficient capacity to test concrete specimens
- ☐R 250,000 lbs. (normal strength concrete)
- ☐ 400,000 lbs. (high strength concrete)
(**NOTE:** The testing machine shall conform to all the requirements of ASTM Practices E4, Load Verification of Testing Machines and ASTM Test Method C39 for Compressive Strength of Cylindrical Concrete Specimens. The machine shall be verified annually in accordance with ASTM Practices E4 and documentation of verification shall be available.)
- ☐R Confirmed adequate equipment/facilities for preparing concrete test specimens in accordance with ASTM Method C192, Making and Curing Concrete Test Specimens in the Laboratory
- ☐R Confirmed that paperwork has been maintained regarding lab verification that equipment conforms to ASTM specifications, i.e. single use molds, reusable molds, flexural beam molds, cube molds
- ☐R Confirmed that physical testing of capping compounds conform to ASTM guidelines and that test records are maintained
- ☐ Confirmed, that equipment prescribed for the following ASTM test methods conforms to ASTM guidelines and that the lab is maintaining equipment maintenance and applicable calibrating records.
- ☐ C142, Test Methods for Clay Lumps and Friable Particles in Aggregate
 - ☐ Balance to .1% of weight of test sample
 - ☐ Oven (temperature 110 +/- 5 degrees)
- ☐ C123, Test Method for Lightweight Pieces and Aggregate
 - ☐ Balance to .1 g
 - ☐ # 50/ 4 sieve
 - ☐ Hydrometer

AGENCY SURVEY CHECKLIST

- ___ C117, Test Method for Materials Finer Than #200 Sieve in Mineral Aggregates by Washing
(**NOTE:** Includes physical inspection of sieves)
___R # 200/ 16 sieve
___R Oven
___R Dispersing agent (i.e. dish washing soap)
- ___ C40, Test Method for Organic Impurities in Fine Aggregates for Concrete
___R Reference card or color solutions
___R Solution or sodium hydroxide to make solution
___R Graduated glass container
- ___ C136, Method of Sieve Analysis of Fine and Coarse Aggregates
(**NOTE:** Includes physical inspection of sieves)
___R Balance
___R Sieves
- ___ C128, Test Method for Specific Gravity and Absorption of Fine Aggregate
___R Cone & Tamper
___R Balance
___R Pycnometer Jar
- ___ C127, Test Method for Specific Gravity and Absorption of Course Aggregate.
___R Balance
___R Water tank
___R Wire mesh container
- ___ C566, Test Method for Total Moisture Content of Aggregates by Drying
___R Balance
___R Oven (temperature 110 +/- 5 degrees)
- ___ C29, Test Method for Unit Weight and Voids in Aggregate
___R Balance
___R Tamping rod
___R Unit weight bucket
___R Plate glass
- ___ Test for flexural strength of concrete in accordance with ASTM Test Methods C31 and C78, for Flexural Strength of Concrete
(**NOTE:** Using Simple Beam and Third-point Loading)
- ___ ASTM C131, Test Methods for Resistance to Degradation of Small Size Coarse Aggregate by Abrasion and Impact (Los Angeles Machine)
___ In-house
___ External

AGENCY SURVEY CHECKLIST

- ___ ASTM C88, Test Method for Soundness of Aggregates (Sodium Sulfate or Magnesium Sulfate & Hydrometer)
 - ___ In-house
 - ___ External
- ___ Physical and chemical analysis of cement (Chemistry Laboratory)
 - ___ In-house
 - ___ External
- ___ Testing of curing compounds, admixtures and related material (Chemistry Laboratory)
 - ___ In-house
 - ___ External
- ___ Determination of modulus of elasticity (Jig with Dial Gauges and Break Machine)
 - ___ In-house
 - ___ External
- ___ A screw (or hydraulic) type testing machine of sufficient capacity to test any tendon specimen which may be involved-normally a multiple range machine with at least 200,000 lb. capacity, jaws extensometer
 - ___ In-house
 - ___ External

4.1.2 Field Inspection:

- ___ Confirmed that the lab is maintaining calibration logs on the equipment required for the following ASTM test methods and that they are verifying that personnel is performing testing as per guidelines:
- ___ C231, Test Method for Air Content of Freshly Mixed Concrete by the Pressure Method (air meters)
 - ___R Air pot
 - ___ C173, Test Method for Air Content of Freshly Mixed Concrete by the Volumetric Method
 - ___ Volume metric type air meter-"roll-o-meter"
 - ___ C31, Test Method for Making and Curing Concrete Test Specimens in the Field
 - ___R Cylinder molds
 - ___R Tamping rods
- ___ C172, Test Method of Sampling Freshly Mixed Concrete
 - ___R Cylinder molds
 - ___R Tamping rods
- ___ C143, Test Method for Slump of Portland Cement Concrete
 - ___R Slump cones
 - ___R Tamping rods
 - ___R Scoop

AGENCY SURVEY CHECKLIST

- ___ C138, Test Method for Unit Weight, Yield and Air Content (Gravimetric) of Concrete
 - ___R Air pot
 - ___R Strike-off plate
 - ___R Thermometer
- ___ C1064, Test Method for Temperature of Freshly Mixed Concrete
 - ___R Thermometer

Category (Reinforced Concrete and Prestressed Concrete) Inspector Notes:

4.2 SHOTCRETE

(Reinforced Concrete registration is a prerequisite for this registration)

4.2.1 Laboratory Equipment:

- ___ Confirmed coring equipment (or access to equipment) capable of removing samples from shotcrete panels
 - ___R Coring machine
 - ___R Compression machine
- ___R Confirmed equipment (or access to equipment) for preparing perpendicular core ends
 - ___ Cut-off saw

Category (Shotcrete) Inspector Notes:

4.3 STRUCTURAL MASONRY

4.3.1 Laboratory Equipment:

- ___R Confirmed a screw (or hydraulic) type compression machine of sufficient capacity to test any specimen which may be involved in masonry construction - normally a multiple range machine with at least 250,000 lb. capacity.
(**NOTE:** A 500,000 lb. capacity machine should be accessible)
(The testing machine shall conform to all the requirements of ASTM E4, "Load Verification Testing Machines." The machine shall be calibrated annually and a report giving details of the calibration shall be readily available.)

AGENCY SURVEY CHECKLIST

- ☐R Confirmed adequate facilities for curing mortar and grout specimens in accordance with ASTM C192.
 - ☐ Curing room temperature and humidity are being maintained, or
 - ☐ Curing tank temperature and water solutions are being maintained
- ☐R Confirmed adequate facilities and equipment for testing mortar in accordance with ASTM C780 & grout in accordance with 4 ASTM C1019
- ☐R Confirmed adequate procedures and documentation pertaining to verification that equipment conforms to IBC and ASTM specifications, e.g. single use molds, reusable molds, and cube molds
- ☐R Confirmed that physical testing of capping compounds conforms to ASTM guidelines and that test records are maintained
- ☐R Confirmed adequate facilities for curing prisms in accordance with ASTM C1314
- ☐R Confirmed adequate facilities for capping prisms in accordance with ASTM C1314
- ☐R Confirmed use of proper loading platens of thickness and hardness in accordance with ASTM C1314

Category (Structural Masonry) Inspector Notes:

4.4 STRUCTURAL STEEL AND BOLTING

4.4.1 Laboratory Equipment:

- ☐ Confirmed access to facilities for mechanical testing of steel
 - ☐ In-house
 - ☐ External
- ☐ Confirmed access to facilities for analysis of constituents and alloying elements of structural steel (Chemistry Laboratory)
 - ☐ In-house
 - ☐ External

AGENCY SURVEY CHECKLIST

4.4.2 Field Inspection:

- ___ Confirmed the following equipment:
- ___R Steel tape, rule, calipers and other appropriate measuring equipment
 - ___R Inspector's identification stamp or tags
 - ___R Torque wrench for high strength bolts
 - ___R Tension calibration device (Skidmore or equivalent)
 - ___R Feeler gauges for load indicator washers

Category (Structural Steel & Bolting) Inspector Notes:

4.5 STRUCTURAL WELDING

4.5.1 Laboratory Equipment:

- ___ Confirmed access to facilities for mechanical testing of welded samples
- ___ In-house
 - ___ External

4.5.2 Field Inspection:

- ___ Confirmed the following equipment:
- ___R Steel tape, rule, calipers and other appropriate measuring equipment
 - ___R Weld dimension gage
 - ___R Weld viewing shield
 - ___R Strong hand light
 - ___R Thermometer or temperature measuring crayons
 - ___R Inspector's identification stamp or tags

AGENCY SURVEY CHECKLIST

4.5.3 Nondestructive Testing:

___ Confirmed access to nondestructive testing which meets the requirements of ASTM E543, Practice for Determining the Qualifications of Nondestructive Testing Agencies

___ In-house
___ External

Category (Structural Welding) Inspector Notes:

4.6 SPRAY – APPLIED FIRE – RESISTIVE MATERIALS

4.6.1 Laboratory Equipment:

___R Confirmed oven capable of drying samples to constant weight at 120 degrees F and fifty percent (50%) relative humidity.
___R Confirmed scales of sufficient accuracy for obtaining dry weight
___ Glass Beads
___ Funnel
___ 200 mL container

4.6.2 Field Inspection:

___R Confirmed procedures used for sampling of materials
___ Confirmed the following equipment
___R Depth measuring devices
___R Template
___R Tape
___R Adhesion equipment
___R Epoxy
___R Jar lids
___R Calibrated scale

Category (Spray-applied Fire-resistive Materials) Inspector Notes:

AGENCY SURVEY CHECKLIST

4.7 STRUCTURAL WOOD

4.7.1 Laboratory Equipment (N/A)

4.7.1.1 Laboratory Equipment – Mass Timber (N/A)

4.7.2 Field Inspection

___ Confirmed the following equipment:
___R Moisture Meter
___R Tape Measure
___R Pull Test Assembly

4.7.2.1 Field Inspection – Mass Timber

___ Confirmed the following equipment:
___R Wood Moisture Meter
___R Tape Measure
___R Pull Test Assembly
___R Protractor
___R Torque Wrench
___R Outside Calipers

Category (Structural Wood) Inspector Notes:

4.8 COLD – FORMED STEEL FRAMING

4.8.1 Laboratory Equipment (N/A)

4.8.2 Field Inspection

___R Fillet Weld Gauge
___R Magnifying Glass
___R Flashlight
___R Steel Tape, Rule, Caliper
___R Weld Viewing Shield

Category (Cold-Formed Steel Framing) Inspector Notes:

AGENCY SURVEY CHECKLIST

4.9 POST – INSTALLED ANCHORS

4.9.1 Laboratory Equipment (N/A)

4.9.2 Field Inspection

- ☐R Pull Test Assembly
- ☐R Steel Tape, Ruler, Caliper
- ☐R Torque Wrench

Category (Post-Installed Anchors) Inspector Notes:

4.10 FIRE – RESISTANT PENETRATIONS AND JOINTS

4.10.1 Laboratory Equipment:

- ☐R Calibrated scale/balance
- ☐R Thickness Gauge
- ☐R Outside Caliper
- ☐R Mil Thickness Gauge

4.10.2 Field Inspection:

- ☐R Razor Knife
- ☐R Steel tape measure, ruler
- ☐R Thickness Gauge/depth measuring device
- ☐R Outside/Digital Caliper
- ☐ Strong hand light
- ☐ Magnifying glass
- ☐ Inspector identification markers
- ☐ Drill bits
- ☐ Spatula or putty knife
- ☐R Mil Thickness Gauge

Inspection procedure and required forms:

- ☐ Inspection procedure for E 2174
- ☐ Inspection procedure for E 2393
- ☐ Inspection forms for E-2174
- ☐ Inspection forms for E -2393

Category (Fire-Resistant Penetrations and Joints) Inspector Notes:

- 5. CODES AND STANDARDS – *current edition per Washington State Building Code***
- 5.1 BASIC** (any and all types of work)
- 5.1.1** International Building Code
 - 5.1.2** American Society for Testing and Materials (ASTM) Standards (applicable to the types of work performed by the agency)
- 5.2 REINFORCED CONCRETE**
- 5.2.1** American Concrete Institute (ACI) Standard 318
 - 5.2.2** American Concrete Institute (ACI) Collection of Concrete Codes, Specifications, and Practices 9-Volume Set
 - 5.2.3** American Concrete Institute (ACI) Manual of Concrete Inspection (MNL-2/ACI-311.1R)
 - 5.2.4** Portland Cement Association (PCA) Design & Control of Concrete Mixtures
 - 5.2.6** Concrete Reinforcing Steel Institute (CRSI) Manual of Standard Practice
- 5.3 STRUCTURAL MASONRY**
- 5.3.1** Masonry Institute (MI) Inspectors Handbook Reinforced Concrete Masonry Construction
 - 5.3.2** Masonry Institute (MI) Reinforced Grouted Brick Masonry
 - 5.3.3** TMS 402/602 Building Code Requirements and Specifications for Masonry Structures
- 5.4 PRESTRESSED CONCRETE**
- 5.4.1** Manual for Quality Control for Plants and Production of Precast and Prestressed Concrete Products (PCI Manual 116)
 - 5.4.2** Field Procedures Manual for Unbonded Single Strand Tendons (PTI)
- 5.5 STRUCTURAL STEEL AND BOLTING**
- 5.5.1** American Institute for Steel Construction (AISC) Manual of Steel Construction
 - 5.5.2** American Institute for Steel Construction (AISC) 341 – Chapter J “Special Inspection of Seismic Force-resisting Systems”
 - 5.5.3** American Institute for Steel Construction (AISC) 360 – Chapter N “Minimum Requirements for Inspection of Structural Steel Buildings”
 - 5.5.4** Steel Joist Institute (SJI) Code of Standard Practice

5.6 STRUCTURAL WELDING

- 5.6.1** American Welding Society (AWS) Structural Welding Code – Steel (D1.1)
- 5.6.2** American Welding Society (AWS) Structural Welding Code – Sheet Steel (D1.3)
- 5.6.3** American Welding Society (AWS) Structural Welding Code – Reinforced Steel (D1.4)
- 5.6.4** Structural Welding Code – Seismic Supplement (AWS D1.8)
- 5.6.5** American Welding Society (AWS) Guide for Visual Inspections of Welds (AWS B1.11)
- 5.6.6** AWS Standard Symbols for Welding (A2.4)
- 5.6.7** American Institute for Steel Construction (AISC) 360 - Chapter N “Minimum Requirements for Inspection of Structural Steel Buildings” – 360
- 5.6.8** American Institute for Steel Construction (AISC) 341 – Chapter J “Special Inspection of Seismic Force-resisting Systems” – 341

5.7 SPRAY – APPLIED FIRE – RESISTIVE MATERIALS

- 5.7.1** Standard Practice for Testing and Inspection of Field Applied Sprayed Fire-Resistive Materials (AWCI 12A)
- 5.7.2** Standard Practice for the Testing and Inspection of Thin-Film Intumescent Fire-Resistant Materials (AWCI 12B)
- 5.7.3** ASTM E605 Standard Test Methods for Thickness and Density of Sprayed Fire-Resistive Materials (SFRM) Applied to Structural Members
- 5.7.4** ASTM E736 Standard Test Method for Cohesion/Adhesion of Sprayed Fire-Resistive Materials Applied to Structural Members

5.8 STRUCTURAL WOOD

- 5.8.1** International Building Code
- 5.8.2** American Wood Council (AWC) – National Design Specification (NDS) for Wood Construction with Commentary
- 5.8.3** American Plywood Association Introduction to Lateral Design
- 5.8.4** American Plywood Association Engineered Wood Construction Guide
- 5.8.5** American Wood Council Special Design Provision for Wind and Seismic (SDPWS)
- 5.8.6** ASTM – F1667 Standard Specification for Driven Fasteners: Nails, Spikes and Staples

5.9 MASS TIMBER

- 5.9.1** International Building Code
- 5.9.2** ANSI/APA PRG 320 Standard for Performance-Rated Cross-Laminated Timber
- 5.9.3** CLT Handbook
- 5.9.4** Nail Laminated Timber US Design Construction Guide
- 5.9.5** Structural Screw Catalog (MTC Solutions)
- 5.9.6** American Wood Council (AWC) – National Design Specification (NDS) for Wood Construction with Commentary
- 5.9.7** Simpson Strong-Tie Fastening Systems Technical Guide – Mass Timber / Cross – Laminated Timber Fastening

5.10 COLD-FORMED STEEL FRAMING

- 5.10.1** International Building Code (Chapter 2, 17 and 22)
- 5.10.2** ASTM C955 Standard Specification for Load Bearing Transverse and Axial Steel Studs, Runners, Tracks & Bracing or Bridging, for Screw Application of Gypsum Panel Products & Metal Plaster Bases
- 5.10.3** ASTM C 1007 – Standard Specification for Installation of Load Bearing (Transverse and Axial) Steel Studs and Related Accessories
- 5.10.4** ASTM C 1513 Standard Specification for Steel Tapping Screws for Cold-Formed Steel Framing Connections
- 5.10.5** AISI S230 Prescriptive Methods for 1 and 2 Family Dwellings
- 5.10.6** AISI S240 North America Standard for Cold-Formed Steel Structural Framing
- 5.10.7** AISI S400 North American Standard for Seismic Design of Cold-Formed Steel Structural Systems
- 5.10.8** AWS D1.3 Structural Welding Code - Sheet Steel
- 5.10.9** SSMA Product Technical Information from the Steel Stud Manufacturers Association

5.11 SHOTCRETE

- 5.11.1** International Building Code
- 5.11.2** Guide to Shotcrete (ACI 506R)
- 5.11.3** Specification for Shotcrete (core grading standard) 506.2.13
- 5.11.4** ASTM C1140 Standard Practice for Preparing and Testing Specimens from Shotcrete Test Panels
- 5.11.5** ASTM C1385 Standard Practice for Sampling Materials for Shotcrete
- 5.11.6** ASTM C1604 Standard Test Method for Obtaining and Testing Drilled Cores of Shotcrete

5.12 POST – INSTALLED ANCHORS

- 5.12.1** Building Code Requirements for Structural Concrete (ACI 318)
- 5.12.2** Qualification of Post-Installed Expansive Anchors in Concrete (ACI 355.2)
- 5.12.3** Qualification of Post-Installed Adhesive Anchors in Concrete (ACI 355.4)

5.13 FIRE – RESISTANT PENETRATIONS AND JOINTS

- 5.13.1** International Building Code
- 5.13.2** ASTM E2174 Standard Practice for On-Site Inspection of Installed Firestop Systems
- 5.13.3** ASTM E2393 Standard Practice for On-Site Inspection of Installed Fire-Resistive Joint Systems and Perimeter Fire Barriers
- 5.13.4** ICC Special Inspection Manual

Section 5 Inspector Notes: